



November 21, 2013

Mr. Robert Solleder
Douglas Barwick, Inc.
150 California Avenue
Box 756
Brockville, ON K6V 5W1

Re: Certification to NSF/ANSI 61, NSF/ANSI 372

Dear Mr. Solleder,

NSF International has certified the attached list of stainless steel pipe, fittings and fabricated products produced by Douglas Barwick, Inc. to NSF/ANSI Standard 61: Drinking Water System Components – Health Effects, as well as NSF/ANSI Standard 372: Drinking Water Systems Components – Lead Content.

This certification to NSF/ANSI 61 Annex G, NSF /ANSI 372 verifies compliance with the lead content requirements for “lead free” plumbing as mandated by California, Vermont, Maryland, and Louisiana state laws as well as the U.S. Safe Drinking Water Act requirements scheduled to take effect January 4, 2014.

This certification also verifies compliance with the requirements of the Texas Administrative Code Title 30, Part 1, Chapter 290, Subchapter D, Section 290.44 part a 1 and 2 which mandates that pipes and related products be NSF/ANSI Standard 61 Certified.

Please feel free to contact me directly if you have any questions or concerns.

Sincerely,

A handwritten signature in black ink, appearing to read "D Purkiss".

David Purkiss
General Manager
Water Treatment and Distribution Systems
NSF International
Phone: +1-734-827-6855
Email: Purkiss@nsf.org